

OSHA 1910.157: visual inspection monthly; maintenance check yearly, with the date recorded and kept for a year after the last entry.

Extinguisher # / location	Type	Annual service date	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Notes

Monthly visual check: initial the month when every item is OK

- ☐ In its place, visible, nothing blocking it
- ☐ Pressure gauge in the green
- ☐ Pin and tamper seal intact
- ☐ No dents, rust, leaks or clogged nozzle
- ☐ Instructions on the label readable
- ☐ Service tag present and in date

Reviewed by: _____ Date: _____